

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1496:172 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Firecom, Inc., 39-27 59th Street, Woodside, NY 11377
Contact: Howard Kogen (718) 899-6100 Fax (718) 899-1932

DESIGN: Models FCH70-24MCW and FCH90-24MCW synchronized or non-synchronized multi-candela chime strobes. Units may be followed by suffixes to designate lens orientation, lens lettering and plate color. Models with suffix -W are wall mount. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 6-33 VDC
Flash rate: 60 flashes/min
Candela: Selectable 15cd, 30cd, 75cd or 110cd

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. For wall mount only.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as chime strobes suitable for the hearing impaired when used in conjunction with separately listed electrically compatible fire alarm control units. For indoor use only. For synchronized strobes, Models FSM-12/24 or FDSM-12/24 sync module must be used.

XLF: 7125-0785:151

02-04-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 22, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager